



Project Number: 3081448

Date Issued: 2/27/2010

Certificate of Conformance #: 3072346-004

Test Report Number: 3081448CRT-040b

Applicant:

Perma-Cote
1100 US Hwy 271 South
Gilmer, TX 75644

Applicant Contact: Mr. Pete Scarborough

Manufacturer:

Perma-Cote
1100 US Hwy 271 South
Gilmer, TX 75644

Mfg. Contact: Mr. Tim Blume

Dear Mr. Pete Scarborough;

Intertek is pleased to provide this letter report covering the follow-up testing on your PVC Coated Conduit: Perma-Cote Threaded and Not Threaded Catalog # 075-CON 1/2". The samples were selected from your manufacturer facility, Perma-Cote TX, by the Intertek Inspector Mr. Joe Fletcher for Quarter 1 2010 Quarterly Follow-up Testing.

Intertek has certified Plasti-Bond's compliance with ETL PVC-001. Initial certification validated adhesion performance for 90 days in heat/humidity exposure of 150 degrees F and 95% relative humidity and 200 hours in hot water immersion at a temperature of 95 degrees C plus/minus 5 degrees C. On-going compliance is verified quarterly by testing to the Intertek High Temp H2O PVC Coating Test Procedure for 200 hours.

The testing was performed at Intertek located in Cortland, NY on 2/18/10 through 2/26/10 to the Intertek High Temp H2O PVC Coating Adhesion Test Procedure for 200 hours in H2O at a temperature of 95° C ± 5° C and found to be in compliance with the applicable requirements of the test specification.

We have appreciated this opportunity to be of service to you. If there are any questions regarding this letter or if you require any other services offered by Intertek, Please do not hesitate to contact us.

Sincerely,

Kathy Heath
Project Coordinator
Global Cabling Products Testing
Phone: (607) 758-6641
Email: kathy.heath@intertek.com

Antoine Pelletier
Engineer
Global Cabling Products Testing
Phone: (607) 758-6718
Email: antoine.pelletier@intertek.com

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program



Client: Perma-Cote		Project #: 3081448 Quarter 1 2010		Test Start Date: 2/26/10	
Specification: Intertek High Temp H2O PVC Coating Adhesion Test Procedure for 200 hours in H2O at a temperature of 95° C ± 5° C				Test: Adhesion of PVC Coating	
Test Sample	Un-Aged	Aged			
Test Date					
Perma-Cote Color Green Un-Threaded					
Sample 1	10	10			
Sample 2	10	10			
Sample 3	10	10			
Perma-Cote Color Green Threaded					
Sample 1	10	10			
Sample 2	10	10			
Sample 3	10	10			
At time of Test	Equipment Used	Model #	Control #	Calibration Due Date	
	Environmental Chamber	DKN400	N/A*	N/A	
	Humidity Temperature Meter	HH314A	T1309	5/7/10	
	* The Oven temperature is monitored using the HH314 Humidity Temperature Meter instead of the oven itself in order to achieve better measurement accuracy				
Test Technician:	John Cash				
Date:	February 18, 2010 to February 26, 2010				
Notes:					

The results of each external adhesion test were ranked in accordance with the following table.

Rating	Description
0	Poor
2	Poor – Spotty
4	Spotty – Poor
6	Spotty
8	Good – Spotty
10	Good